From: Claire Braybrook <Claire.Braybrook@huntingdonshire.gov.uk>
Sent: 27 March 2025 16:56:25 UTC+01:00
To: "Jennifer Wallis" <Jennifer.Wallis@huntingdonshire.gov.uk>
Cc: "DMAdmin" <Development.ManagementAdmin@huntingdonshire.gov.uk>
Subject: 25/00375/FUL - Cambridgeshire Constabulary Hinchingbrooke Park Hinchingbrooke Park Road Huntingdon

Hi Kirsty,

Proposal: Installation of replacement generators
Location: Cambridgeshire Constabulary Hinchingbrooke Park Hinchingbrooke Park Road Huntingdon PE29 6NP
Planning Ref: 25/00375/FUL
EH Ref: 406418

Thank you for providing confirmation that the generators are for standby use only and will only be operated in an emergency (mains electrical supply outage for the site) and for limited maintenance checks and testing. I would advise maintenance checks and testing should not be completed outside the following hours: 08:00 – 18:00 during the working week (taken as Monday to Friday).

From the information supplied I can confirm that if the maintenance and testing occurs in line with the information supplied in your email of todays date, and during less sensitive hours, as advised above, I have no issues to raise.

If you have any queries or wish to discuss this matter further please don't hesitate to contact me.

Kind regards,

Claire.

Huntingdonshire DISTRICT COUNCIL

Claire Braybrook
Environmental Health Officer (Public Protection - Environmental Health) MCIEH, CEnvH, Dip (IoA)

Phone 01480 388 284
Mobile 07810 637 579



Any comments represent the informal opinion of an officer of Huntingdonshire District Council. These comments are made on a without prejudice basis.