DAVID THIRTLE
AIRCON & REFRIGERATION LTD
EMAIL: info@dtair.uk

TO: Tom Highland

DATE: 15/10/2025

REF: Condenser units on site.
ESSO, 66-76 Cambridge Street, St Neots
Cambs PE19 1PJ

To, Tom Highland

Condensing units on site as listed. Db at 1m.

1 x OP-MSBM014DPW05G walk in chiller. 53DB Max

1 x OP-LSQM068NTW05G walk in freezer. 52db(A) Max

1 X LG-UUD1-U30 AirCon. 54db Max

1 X J & E HALL JEHS-0400-B3-M-3. Display 56db Max

2 X J & E HALL JEHS-0200-B2-M-3. Display 53db Max each.

Please be advised the units very rarely run at maximum together. The LG Airconditioning unit is an inverter so 80% of the time is running at 20-40% capacity, approximately 20-30db. After the shop is closed there is a major reduction in refrigeration use due the new energy efficient display cases (with doors).

Kind Regards

David Thirtle TMInstR

David Thirtle AirCon & Refrigeration Ltd
Unit 3, Mereside Farm
Mereside Drove
Ramsey Mereside
Huntingdon
Cambs
PE26 2UE

Vat 883 3379 87
Tel Office: 01733 844752
Mobile: 07727 036755
Email: info@dtair.uk