From: Aaron Morley
Sent: 25 October 2024 13:53
To: DMAdmin; Lucy Pateman
Subject: 24/80344/COND Sawtry Village Academy

Hi Lucy

Planning Ref: 24/80344/COND
Env Health Ref: 400080

Sawtry Village Academy, Fen Lane, Sawtry Huntingdon PE28 5TQ
Discharge of condition 5 of (noise management plan) of 23/00161/FUL

I have reviewed the updated Noise Management Plan where they have added paragraph 21 which now includes all of the previously missing requirements. Therefore, I have no objection to the approval of the plan in support of Condition 5. The condition requires that all noise mitigation measures outlined within the plan be retained.

Best regards,
Aaron

Aaron Morley
Environmental Health

From: Aaron Morley
Sent: 05 September 2024 12:44
To: Dmadmin@huntingdonshire.gov.uk; Lucy Pateman <Lucy.Pateman@huntingdonshire.gov.uk>
Subject: RE: Planning consultation notification 24/80269/COND

Hi Lucy

Planning Ref: 24/80269/COND
Env Health Ref: 397840

Sawtry Village Academy, Fen Lane, Sawtry, Huntingdon PE28 5TQ
Discharge of Conditions 5 (Noise Management Plan), 6 (Acoustic Fence) and 7 (Footpath Lighting) for 23/00161/FUL

I have reviewed the Noise Management Plan submitted in support of Condition 5. The condition requires a list of measures, very few of which have been addressed in the Noise Management Plan. I can therefore not recommend discharge of Condition 5. I copy the condition below and highlight some of the points not covered.

5. Condition. Prior to first use of the development hereby approved, a noise management plan shall be submitted to and approved in writing by the Local Planning Authority. The noise management plan shall include all other mitigation measures such as neoprene isolators to separate fence panels from posts, netting to stop balls hitting the fence, use of whistles, placement of any signage, terms of use/behaviour policy and complaint investigation procedure. Any required noise mitigation shall be fully implemented before the use hereby permitted is commenced and retained as such.

The acoustic fence details outlined in Drawing No. 2637/OVER/01, **Revision F**, dated 11 June 2024, is acceptable and I have no objection to its approval in support of Condition 6.

Best regards,

Aaron

Aaron Morley BSc(Hons) MSc(EngGeol) MSc(EnvHealth) PGDip(Acous) FGS MCIEH CEnvH REnvH AFPH

Environmental Protection Officer
Phone 01480 388360
Mobile 07810 637573

-----Original Message-----
From: Dmadmin@huntingdonshire.gov.uk <Dmadmin@huntingdonshire.gov.uk>
Sent: Friday, August 16, 2024 12:02 PM
To: Environmental Health <Environmental.Health@huntingdonshire.gov.uk>
Subject: Planning consultation notification 24/80269/COND

Dear Sir/Madam

Please find correspondence from Development Management at Huntingdonshire District Council attached to this email in relation to the following application for Discharge of planning condition(s).

Proposal: Discharge of Conditions 5 (Noise Management Plan), 6 (Acoustic Fence) and 7 (Footpath Lighting) for 23/00161/FUL

Site address: Sawtry Village Academy Fen Lane Sawtry

Reference: 24/80269/COND

Huntingdonshire DC Development Management