PLANNING CONSULTATION RESPONSE

To Marie Roseaman Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 24/80413/COND Date In: 27/11/24 Date Out: 23/12/24	**Contact**: Jo Challis

RE: ***Application description***

Proposal: Discharge of Condition 12 (drainage measures) for 21/00412/FUL
Location: The Barn Top Lane Abbotsley St Neots PE19 6UH

Following a review of the documents provided to the Highway Authority as part of the above planning application it was noted that on Drawing ST-2730-04 Indicative Headwall and Dry Swale Arrangements the western side of the access has flush bull nose kerbs to enable the water from the access to drain into the swale. However, the image on Google Street View dated August 2024 shows half battered kerbs which channel the water from the access onto the highway.

Therefore, Condition 12 (drainage measures) cannot be discharged.

Jo Challis
Highways Development Management Engineer