PLANNING CONSULTATION RESPONSE

To Jennifer Wallis Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 25/80082/COND Date In: 18/03/25 Date Out: 26/03/25	**Contact**: Sonia Hansen

RE: ***Application description***

Proposal: Discharge of Condition 9 (Gates) for 23/00211/FUL
Location: Land Adjacent To Thorns Farm Hamerton Road Alconbury Weston

Following a review of the documents provided as part of the above discharge of conditions the Local Highway Authority offers no objection to the position of the gates as shown on drawing number 004 as they are set back at least 5m from the near edge of the highway carriageway.

There seems to be a discrepancy between the image in the cover letter which shows double swing gates and drawing number 050 which shows electric sliding gates. The Highways Authority is satisfied if the gates are either hung to open inwards or are sliding.

Sonia Hansen
Assistant Engineer
Highways Development Management