[redacted]

From: DevelopmentControl
Sent: 09 May 2025 10:00
To: DevelopmentControl
Subject: Comments for Planning Application 25/00683/FUL

Comments summary

Dear Sir/Madam,

Planning Application comments have been made. A summary of the comments is provided below.

Comments were submitted at 09/05/2025 9:59 AM from Planning Consents.

Application Summary

Address:	Lower Park Farm Agden Green Stonely St Neots PE19 5ET
Proposal:	Retrospective application for the installation of 48 ground-mounted solar array
Case Officer:	[redacted]

Click for further information

Customer Details

Name:	Planning Consents
Email:	[redacted]
Address:	UK Power networks Barton Road Bury st Edmunds

Comments Details

Commenter Type:	Statutory or non- statutory consultee
Stance:	Customer made comments neither objecting to or supporting the Planning Application
Reasons for comment:	
Comments:	We note there are overhead cables on the site running within close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA. In the instance of overhead cables within the vicinity, All works should be undertaken in line with GS6 guidelines as published by the HSE Should any diversion works be necessary because of the development then enquiries should be made to our Customer Connections department. The address is UK Power Networks, Metropolitan house, Darkes Lane, Potters Bar, Herts, EN6 1AG. You can also find support and application forms on our website Moving electricity supplies or equipment | UK Power Networks

Kind regards