PLANNING CONSULTATION RESPONSE

To Hannah Hodges Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 25/80057/COND Date In: 26/02/25 Date Out: 17/03/25	**Contact**: Jo Challis

RE: ***Application description***

Proposal: Discharge of conditions 12(Access Drainage) and 19 (Landscape and Ecological Management Plan) for 22/01802/FUL
Location: Agricultural Buildings Old Manor Farm House Raveley Road Great Raveley

Following a review of the documents provided to the Highway Authority as part of the above planning application, I can confirm that Drawing 3239-05 Detailed Drainage Design provided for Condition 12 (Access Drainage) indicates an Aco type drain at the highway boundary so is suitable for the submission element of the Condition to be discharged.

However, our indicative highway records indicate that the highway boundary in the location of the access is not parallel with the edge of the carriageway. Therefore, the applicant should contact our Asset Information Searches team to obtain an accurate highway boundary before applying to carry out the works to the access Highway searches - Cambridgeshire County Council

Jo Challis
Highways Development Management Engineer