From: Aaron Morley <Aaron.Morley@huntingdonshire.gov.uk>
Sent: 08 April 2025 16:32:07 UTC+01:00
To: "DMAdmin" <Development.ManagementAdmin@huntingdonshire.gov.uk>; "Olivia Manton" <Olivia.Manton@huntingdonshire.gov.uk>
Subject: RE: Planning consultation notification 25/00134/HHFUL

Hi Olivia

Planning Ref: 25/00134/HHFUL
Env Health Ref: 407275

44 Lannesbury Crescent St Neots PE19 6AF
Installation of air source heat pump

I have undertaken my own calculations of the likely sound pressure level at the nearest noise sensitive property and it is 33dB, well below the likely background level (40dB) for this area, so does not warrant a more detailed noise assessment.

We have no objection to this proposal with regard to noise.

Best regards,

Aaron Morley
Environmental Health Officer

-----Original Message-----
From: Dmadmin@huntingdonshire.gov.uk <Dmadmin@huntingdonshire.gov.uk>
Sent: 20 March 2025 11:02
To: Environmental Health <Environmental.Health@huntingdonshire.gov.uk>
Subject: Planning consultation notification 25/00134/HHFUL

Dear Sir/Madam

Please find correspondence from Development Management at Huntingdonshire District Council attached to this email in relation to the following application for Planning Permission.

Proposal: Installation of air source heat pump

Site address: 44 Lannesbury Crescent St Neots PE19 6AF

Reference: 25/00134/HHFUL

Huntingdonshire DC Development Management