PLANNING CONSULTATION RESPONSE

To Marie Roseaman Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 25/80086/COND Date In: 27/03/25 Date Out:23 /04/25	**Contact**: Sonia Hansen

RE: ***Application description***

Proposal: Discharge of conditions 3 (Materials),4 (Landscaping)and 9 (Surface water highway) of 18/01305/FUL (retrospective)

Location: 62 Mandeville Road Brampton Huntingdon PE28 4SB

Following a review of the documents provided to the Highway Authority as part of the above discharge of conditions I have noted that Drawing number 22517_01 shows buff / cream coloured gravel to parking / turning area which will be permeable to prevent highway run off.

The Highway Authority has no objection to Condition 9 of this permission being cleared.

Sonia Hansen
Assistant Engineer
Highways Development Management