PLANNING CONSULTATION RESPONSE

To Charlotte Dew Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 25/00669/ADV Date In: 02/05/25 Date Out: 15/05/25	**Contact**: Sonia Hansen

RE: ***Application description***

Proposal: Erection of 4 x illuminated and 4 x non-illuminated signs to exterior of building

Site address: Public House The Cuckoo 20 Oundle Road

Based on the information submitted, from the perspective of the Local Highway Authority the proposed development is acceptable."

If the Local Planning Authority are mindful to approve the application, please append the following Conditions to any consent granted:

HDMC 33 No part of the source of floodlighting or the illumination of signs shall be directly visible to users of the adjacent public highway.

Reason: In the interests of highway safety.

Sonia Hansen
Assistant Engineer
Highways Development Management