[redacted]

From: Aaron Morley
Sent: 22 November 2024 17:15
To: DMAdmin
Subject: RE: Planning consultation notification 24/02040/HHFUL

Categories: [redacted]

No details have been submitted to identify the sound power level of the ASHP. We should have a specification sheet. A value of 56dB(A) has been inserted into the MCS calculator. Assuming this is correct, we have no objection to this proposal with regard to noise.
Environmental Protection Officer
Environmental Health

-----Original Message-----
From: Dmadmin@huntingdonshire.gov.uk <Dmadmin@huntingdonshire.gov.uk>
Sent: 12 November 2024 11:48
To: Environmental Health <Environmental.Health@huntingdonshire.gov.uk>
Subject: Planning consultation notification 24/02040/HHFUL

Dear Sir/Madam

Please find correspondence from Development Management at Huntingdonshire District Council attached to this email in relation to the following application for Planning Permission.

Proposal: Installation of an Air Source Heat Pump at front of property against the garden shed.

Site address: 2 Wren Walk Eynesbury St Neots

Reference: 24/02040/HHFUL

Huntingdonshire DC Development Management