[redacted]

From: Aaron Morley
Sent: 11 June 2025 09:31
To: DMAdmin
Subject: RE: Planning consultation notification 25/00912/HHFUL

I have reviewed the MCS 020 Manual Sound Calculator for the ASHP and agree with the results, however, it would have been better to have the octave frequency band information for different operating modes rather than a single decibel value. Nevertheless, the location is close to the A1/A14 where the background is likely to be above the standard 40dB used in the MCS calculation, so in this case the proposal is acceptable and I would support this application.

Aaron Morley
Environmental Health Officer

-----Original Message-----
From: Dmadmin@huntingdonshire.gov.uk <Dmadmin@huntingdonshire.gov.uk>
Sent: 27 May 2025 11:28
To: Environmental Health <Environmental.Health@huntingdonshire.gov.uk>
Subject: Planning consultation notification 25/00912/HHFUL

Dear Sir/Madam

Please find correspondence from Development Management at Huntingdonshire District Council attached to this email in relation to the following application for Planning Permission.

Proposal: Installation of air source heat pump to rear

Site address: 29 Riddiford Crescent Brampton Huntingdon

Reference: 25/00912/HHFUL

Huntingdonshire DC Development Management