PLANNING CONSULTATION RESPONSE

To Emily O'Sulivan Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 26/01767/HHFUL	**Contact**: Sonia Hansen Assistant Engineer
Date In: 19/10/2026 Date Out: 21/10/2026	

RE: Application description

Proposal: Erection of single-storey side attached garage and creation of new vehicular access / driveway with permeable block paving

Site address: Mulberry House 10 Kingston Way Wistow Huntingdon PE28 2QP

Following a review of the documents provided to the Highway Authority as part of the above planning application I have noted that the proposal will create a new access onto Kinston Way. Appropriate visibility splays have been demonstrated. The access will require a Section 184 licence from the Highway Authority.

Based on the information submitted, from the perspective of the Local Highway Authority the proposed development is acceptable.

If the Local Planning Authority are mindful to approve the application, please append the following Conditions to any consent granted:

Construction specification

HDMC 14 Prior to the first occupation of the development (or prior to the commencement of the first use) the vehicular access where it crosses the public highway shall be laid out and constructed in accordance with the Cambridgeshire County Council construction specification.

Reason: In the interests of highway safety and to ensure satisfactory access into the site.

Drainage

HDMC 26 The access shall be constructed with adequate drainage measures to prevent surface water run-off onto the adjacent public highway, in accordance with a scheme submitted to and approved in writing by the Local Planning Authority.

Reason: To prevent surface water discharging to the highway.

Informative

HDMI 1 If this development involves work to the public highway, it will require the approval of the County Council as Highway Authority. It is an OFFENCE to carry out any works within the public highway, which includes a public right of way, without the permission of the Highway Authority. Please note that it is the applicant's responsibility to ensure that, in addition to planning permission, any necessary consents or approvals under the Highways Act 1980 and the New Roads and Street Works Act 1991 are also obtained from the County Council.
Public Utility apparatus may be affected by this proposal. Contact the appropriate utility service to reach agreement on any necessary alterations, the cost of which must be borne by the applicant.

Dropped kerb

The applicant should note that the nature of the highway works proposed will necessitate the completion of a Section 184 Highway Works Agreement between the developer and the LHA prior to commencement**.** Dropped kerbs and access protection markings - Cambridgeshire County Council