PLANNING CONSULTATION RESPONSE

To Kevin Simpson Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 25/80182/COND Date In: 27/06/25 Date Out: 30/06/25	**Contact**: Sonia Hansen

RE: ***Application description***

Proposal: Discharge of Condition 10 (Vehicular Access) of 22/01033/S73

Site address: Hare Meadow Cottage Loop Road Keyston

Following a review of the revised drawing entitled 'Driveway at Hare Meadow Cottage' provided to the Highway Authority as part of the above discharge of conditions, I have noted that the plan shows an Aco style drain close to the highway boundary connecting to existing soakaway via existing surface water drainage.

The details as outlined in the plan would be acceptable to the Highway Authority.

Sonia Hansen
Assistant Engineer
Highways Development Management