PLANNING CONSULTATION RESPONSE

To Josh France Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 24/02405/ADV Date In: 30/12/24 Date Out: 16/01/25	**Contact**: Jo Challis

RE: ***Application description***

Proposal: Installation of 7m EV totem sign (new proposed location)
Location: Mecury Petrol Filling Station Needingworth Road St Ives PE27 4NB

Following a review of the documents provided to the Highway Authority as part of the above planning application, it was noted that the totem is to be located between the existing totem and the sales building.

It was also noted that the Application Form states that the luminance levels are 300 cd/m² which is acceptable for a suburban area.

Therefore, no significant adverse effect upon the Public Highway should result from this proposal should it gain benefit of Planning Permission.

Jo Challis
Highways Development Management Engineer