[redacted]

From: [redacted]
Sent: 13 January 2025 09:41
To: DMAdmin; Simpson, Kevin (Planning)
Subject: RE: Planning consultation notification 24/02358/HHFUL

Categories: [redacted]

Hi Kevin

Planning Ref: 24/02358/HHFUL
Env Health Ref: 403147

The Limes Glatton Ways Glatton Huntingdon PE28 5RS
New site entrance gates, new front door canopy, annex extension linking existing garage to dwelling at rear, family room extension to south, solar roof panels and conservation roof lights and air source heat pump installation.

This application includes an Air Source Heat Pump (ASHP) located approximately 8 metres away from the nearest residential neighbour (The Spinney) which could cause unacceptable noise levels.

We can only object to this proposal unless a noise assessment demonstrates that the sound emitting from the ASHP would be acceptable.

In this case, we would accept an assessment undertaken in accordance with the Microgeneration Certification Scheme (MCS), otherwise, the assessment must be produced by a competent person (a Suitably Qualified Acoustician or an Environmental Health Practitioner) in accordance with the methodology of BS4142 : 2014 (*Methods for Rating and Assessing Industrial and Commercial Sound*) and/or its subsequent amendments, to demonstrate that the ASHP design and mitigation measures will ensure that internal sound levels from the ASHP does not exceed 35dB L_{Aeq} 07:00-23:00 in any residential neighbour's habitable room or 30dB L_{Aeq} 23:00-07:00 and 45dB L_{Amax} 23:00-07:00 inside any residential neighbour's bedroom and that sound levels from the ASHP in any residential neighbour's outdoor amenity area does not exceed 50dB $L_{Aeq(1\ hour)}$.

I would be happy to review any additional submission prior to a determination.

Best regards,
[redacted]

Huntingdonshire DISTRICT COUNCIL

[redacted] BSc(Hons) MSc(EngGeol) MSc(EnvHealth) PGDip(Acous) FGS MCIEH CEnvH EHRB REnvH AFPH

Environmental Protection Officer
Phone [redacted]
Mobile [redacted]

CEnvH Chartered Environmental Health Practitioner
Certified Carbon Literate

-----Original Message-----
From: Dmadmin@huntingdonshire.gov.uk <Dmadmin@huntingdonshire.gov.uk>
Sent: 23 December 2024 11:37
To: Environmental Health <Environmental.Health@huntingdonshire.gov.uk>
Subject: Planning consultation notification 24/02358/HHFUL

Dear Sir/Madam

Please find correspondence from Development Management at Huntingdonshire District Council attached to this email in relation to the following application for Planning Permission.

Proposal: New site entrance gates, new front door canopy, annex extension linking existing garage to dwelling at rear, family room extension to south, solar roof panels and conservation roof lights and air source heat pump installation.

Site address: The Limes Glatton Ways Glatton

Reference: 24/02358/HHFUL

Huntingdonshire DC Development Management