From: no-reply-InFlow@anglianwater.co.uk <no-reply-InFlow@anglianwater.co.uk>
Sent: 06 October 2025 17:00:43 UTC+01:00
To: "Control, Development (Planning)" <Development.Control@huntingdonshire.gov.uk>
Subject: Discharge of Condition

Dear Charlotte Dew

Agricultural Buildings Washingley Farm Green End Great Stukeley, 25/80119/COND, PLN-0233501

Thank you for your enquiry to discharge condition relating to the above development site. Please find our comments below.

Foul Water Comments: We have reviewed the proposed drainage plan 3280-02 C which proposes a a connection into Anglian Water foul network. We consider this acceptable to Anglian Water therefore we can recommend condition 9 related to foul drainage strategy to be discharged.

Surface Water Comments: The proposed surface water for the development site is not related to Anglian Water owned assets. Please note Anglian Water has no designated surface water sewers in the area. The applicant proposes to discharge the surface water into a pond therefore we are unable to make comments on the condition 9 related to surface water strategy.

Should you have any queries or comments regarding this please contact us at planningliaison@anglianwater.co.uk or 07929 786 955 quoting reference PLN-0233501.

Kind Regards
Development Services Pre-Development Team

Not you or need help?

Call us on **0345 60 66 087**

This is an automatically generated email, please do not reply to this message.

Anglian Water Services Limited. Registered Office: Henderson House, Lancaster Way, Ermine Business Park, Huntingdon, Cambridgeshire PE29 6XU. Registered in England: No. 2366656. An AWG Company.