PLANNING CONSULTATION RESPONSE

To Charlotte Dew Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 25/00205/FULb Date In: 08/04/25 Date Out: 30/04/25	**Contact**: Jo Challis

RE: ***Application description***

Proposal: Conversion of dwelling into two separate dwellings
Location: 27 Green End Road Sawtry Huntingdon PE28 5UX

Following a review of the documents provided to the Highway Authority as part of the above planning application it was noted that Drawing 001 27 Exisitng and Proposed General Arrangement submitted on 7th April 2025 indicates that the vehicular access will be extended to provide access to the parking area of No. 27.

Therefore, the effect of the proposed development upon the Public Highway should be mitigated if the following Conditions form part of any permission that the Planning Authority is minded to issue in regard to this proposal:-

HDMC 14 Prior to the first occupation of the development (or prior to the commencement of the first use) the vehicular access where it crosses the public highway shall be laid out and constructed in accordance with the Cambridgeshire County Council construction specification.

Reason: In the interests of highway safety and to ensure satisfactory access into the site.

HDMC 26 The access shall be constructed with adequate drainage measures to prevent surface water run-off onto the adjacent public highway, in accordance with a scheme submitted to and approved in writing by the Local Planning Authority.

Reason: To prevent surface water discharging to the highway.

HDMC 28 A metalled surface shall be provided for a minimum distance of 5m along the access road from its junction with the public highway.

Reason: To prevent mud and extraneous material being deposited on the highway.

Vehicular Access

HDMI 1 This development involves work to the public highway that will require the approval of the County Council as Highway Authority. It is an OFFENCE to carry out any works within the public highway, which includes a public right of way, without the permission of the Highway Authority. Please note that it is the applicant's responsibility to ensure that, in addition to planning permission, any necessary consents or approvals under the Highways Act 1980 and the New Roads and Street Works Act 1991 are also obtained from the County Council.

Public Utility apparatus may be affected by this proposal. Contact the appropriate utility service to reach agreement on any necessary alterations, the cost of which must be borne by the applicant.

The applicant should note that the nature of the highway works proposed will necessitate the completion of a Section 184 Highway Works Agreement between the developer and the LHA prior to commencement. Dropped kerbs and access protection markings - Cambridgeshire County Council

Jo Challis
Highways Development Management Engineer