
[redacted]

From: [redacted]
Sent: 29 May 2025 09:24
To: DevelopmentControl
Subject: Discharge of Condition



Dear Kevin Simpson

Rheola Broad Leas St Ives PE27 5PU, 25/80153/COND, PLN-0227673

Thank you for your enquiry to discharge condition relating to the above development site. Please find our comments below.

Foul Water Comments: The foul strategy is acceptable to Anglian Water as per the proposed drainage layout drawing, we can recommend discharge of condition 9

Surface Water Comments: The surface water strategy is acceptable to Anglian Water as per the proposed drainage layout drawing, with a maximum discharge rate of 2l/s to the public combined sewer, we can recommend discharge of condition 8

Should you have any queries or comments regarding this please contact us at planningliaison@anglianwater.co.uk or 07929 786 955 quoting reference PLN-0227673.

Kind Regards

Development Services Pre-Development Team

Not you or need help?

Call us on **0345 60 66 087**



This is an automatically generated email, please do not reply to this message.

Anglian Water Services Limited. Registered Office: Henderson House, Lancaster Way, Ermine Business Park, Huntingdon, Cambridgeshire PE29 6XU. Registered in England: No. 2366656. An AWG Company.