CCC Highways comments 19.12.24 (tracking plan)

Hi Kevin

I am happy with the tracking if a plan showing the dimensions, and the visibility splay are provided then I would have no need of the transport statement.

In that below I note the consultant indicates 5m wide access, (but I can't find a drawing showing this) and then goes onto indicate adequate visibility which is not specific. I note that the surrounding land is within the blue line for land they control so if a plan that is dimensioned with the width (5m) and the splays (2.4m x 120m) is submitted, this can then be conditioned.

Kind Regards

Robin

Robin Hobbs

Highway Development Engineer
West Highway Division,
Stanton Way,
Ermine Street,
Huntingdon,
PE29 6PY.