Amended EH comments 14.01.25

I can see the only windows facing the proposed ASHP will be those from the garage and 1st floor en-suite. Noise won't be a problem at all in that case and we don't need the spec for the ASHP.

Thanks,

Aaron

Aaron Morley

Environmental Protection Officer

Environmental Health