[redacted]

From: DevelopmentControl
Sent: 14 April 2025 09:24
To: DevelopmentControl
Subject: Comments for Planning Application 25/00603/HHFUL

Comments summary

Dear Sir/Madam,

Planning Application comments have been made. A summary of the comments is provided below.

Comments were submitted at 14/04/2025 9:23 AM from [redacted].

Application Summary

Address:	19 Fairfields St Ives PE27 5QQ
Proposal:	Erection of two storey side extension and first floor extension to the rear of dwelling.
Case Officer:	[redacted]

Click for further information

Customer Details

Name:	[redacted]
Email:	[redacted]
Address:	St. Ives Town Hall Market Hill ST. IVES

Comments Details

Commenter Type:	Town or Parish Council
Stance:	Customer made comments in support of the Planning Application
Reasons for comment:	
Comments:	St Ives Town Council recommends support but councillors have asked for flood risk measures to be implemented, i.e. plug sockets to be installed 450mm above ground due to location in flood risk area. Councillors would also like to comment that there may be an effect on neighbouring property with the overlooking wall over the proposed development.

Kind regards