PLANNING CONSULTATION RESPONSE

To Charlotte Dew Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 25/00519/FUL Date In: 29/05/25 Date Out: 29/05/25	**Contact**: Sonia Hansen

RE: ***Application description***

Proposal: Conversion of existing annex and store outbuilding into a 1 bedroom dwelling
Location: Land Rear Of 19 North Street Stilton

Following a review of the documents provided to the Highway Authority as part of the above planning application I have noted that Drawing Number 1178 / 002 revision B dated 13.05.2025 has been updated to show an aco slot drain connecting into existing surface water drain and the driveway hard surfaced for the first 5m and these are now within the red line boundary.

Based on the information submitted, from the perspective of the Local Highway Authority the proposed development is acceptable.

If the Local Planning Authority are mindful to approve the application, please append the following Conditions to any consent granted:

HDMC 14 Prior to the first occupation of the development (or prior to the commencement of the first use) the vehicular access where it crosses the public highway shall be laid out and constructed in accordance with the Cambridgeshire County Council construction specification.

Reason: In the interests of highway safety and to ensure satisfactory access into the site.

HDMC 16 Prior to the first occupation of the development sufficient space shall be provided within the site to enable vehicles to:

a) Enter, turn and leave the site in forward gear
b) Park clear of the public highway
The area shall be levelled, surfaced and drained and thereafter retained for that specific use.

Reason: In the interests of satisfactory development and highway safety.

HDMC 26 The access shall be constructed with adequate drainage measures to prevent surface water run-off onto the adjacent public highway, in accordance with the details shown in Drawing Number 1178 / 002 revision B dated 13.05.2025.

Reason: To prevent surface water discharging to the highway.

HDMC 28 A metalled surface shall be provided for a minimum distance of 5m along the access road from its junction with the public highway.

Reason: To prevent mud and extraneous material being deposited on the highway.

INFORMATIVES

HDMI 1 If this development involves work to the public highway, it will require the approval of the County Council as Highway Authority. It is an OFFENCE to carry out any works within the public highway, which includes a public right of way, without the permission of the Highway Authority. Please note that it is the applicant's responsibility to ensure that, in addition to planning permission, any necessary consents or approvals under the Highways Act 1980 and the New Roads and Street Works Act 1991 are also obtained from the County Council.

Public Utility apparatus may be affected by this proposal. Contact the appropriate utility service to reach agreement on any necessary alterations, the cost of which must be borne by the applicant.

Sonia Hansen
Assistant Engineer
Highways Development Management