From: Aaron Morley <Aaron.Morley@huntingdonshire.gov.uk>
Sent: 27 June 2025 14:21:09 UTC+01:00
To: "DMAdmin" <Development.ManagementAdmin@huntingdonshire.gov.uk>; "Robyn Kerrigan" <Robyn.Kerrigan@huntingdonshire.gov.uk>
Subject: RE: Planning consultation notification 25/01053/HHFUL

Hi Robyn

Planning Ref: 25/01053/HHFUL
Env Health Ref: 411991

8 The Paddocks, Hilton, Huntingdon PE28 9QT
Installation of stand alone air source heat pump to side

A Microgeneration Certification Scheme (MCS) air source heat pump noise calculation has been undertaken and has shown that the predicted sound pressure level at the nearest noise sensitive receptor is likely to exceed the noise limit set out in the guidance. In this case, we would normally request a more detailed noise assessment and mitigation, however as this is a borderline case, we should first request further information about the ASHP.

The ASHP specification identifies one value; the sound power level of 62dBA during heating. This can often be misleading as it may not be expressed in accordance with a recognised test standard or relate to the noisiest operating mode, such as can occur during reverse cycles. Furthermore, information about potentially distinctive sound characteristics such as tonality or intermittency of operation have not been reported. This information should be provided before an informed decision can be made.

Best regards,
Aaron

Huntingdonshire DISTRICT COUNCIL

Aaron Morley BSc(Hons) MSc(EngGeol) MSc(EnvHealth) PGDip(Acous) FGS MCIEH CEnvH EHRB REnvH AFPH

Environmental Health Officer
Phone 01480 388360
Mobile 07810 637573

CEnvH Chartered Environmental Health Practitioner
Certified Carbon Literate

-----Original Message-----
From: Dmadmin@huntingdonshire.gov.uk <Dmadmin@huntingdonshire.gov.uk>
Sent: 24 June 2025 09:28
To: Environmental Health <Environmental.Health@huntingdonshire.gov.uk>
Subject: Planning consultation notification 25/01053/HHFUL

Dear Sir/Madam

Please find correspondence from Development Management at Huntingdonshire District Council attached to this email in relation to the following application for Planning Permission.

Proposal: Installation of stand alone air source heat pump to side

Site address: 8 The Paddocks Hilton Huntingdon

Reference: 25/01053/HHFUL

Huntingdonshire DC Development Management