From: Claire Braybrook <Claire.Braybrook@huntingdonshire.gov.uk>
Sent: 25 March 2025 16:11:00 UTC+00:00
To: "Olivia Manton" <Olivia.Manton@huntingdonshire.gov.uk>
Cc: "DMAdmin" <Development.ManagementAdmin@huntingdonshire.gov.uk>
Subject: 25/00213/HHFUL - 19 Snowy Way Hartford
Categories: Jason

Hi Olivia,

Proposal: Proposed shower room and installation for a condenser and re-location of tea point
Location: 19 Snowy Way Hartford Huntingdon PE29 1LQ
Planning Ref: 25/00213/HHFUL
EH Ref: 405645

Thank you for the additional information. I can confirm that looking at the sound levels of the proposed unit and taking into consideration the shielding, distances and nearest sensitive receptor points it is considered the installation of this unit would not cause a significant adverse effect, and therefore I have no issues to raise and my earlier objection can be removed.

If you have any queries or wish to discuss this matter further please don't hesitate to contact me.

Kind regards,

Claire.

Claire Braybrook
Environmental Health Officer (Public Protection - Environmental Health) MCIEH, CEnvH, Dip (IoA)

Phone 01480 388 284
Mobile 07810 637 579



Any comments represent the informal opinion of an officer of Huntingdonshire District Council. These comments are made on a without prejudice basis.