PLANNING CONSULTATION RESPONSE

To Andrea Dollard Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 25/00295/ADV Date In: 10/03/25 Date Out: 26/03/25	**Contact**: Sonia Hansen

RE: ***Application description***

Proposal: 1 x internally illuminated fascia sign Smiths advanced 2 x directional signs.
Location: 5 Percy Road Huntingdon PE29 6SZ

Following a review of the information submitted, from the perspective of the Local Highway Authority the proposed development is acceptable.

I note that the illuminated sign on the building is remote from the public highway and is approximately 12sqm with illumination level that will not exceed 136.62 Cd per m2. If the Local Planning Authorty are mindful to approve the application, please append the following Conditions to any consent granted:

HDMC 33 No part of the source of floodlighting or the illumination of signs shall be directly visible to users of the adjacent public highway.

Reason: In the interests of highway safety

Sonia Hansen
Assistant Engineer
Highways Development Management