PLANNING CONSULTATION RESPONSE

To Olivia Manton Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 25/80063/COND Date In: 28/02/25 Date Out: 07/04/25	**Contact**: Sonia Hansen

RE: ***Application description***

Proposal: Discharge of conditions 3 (materials), 5 (hard soft landscaping), 8 (cycle storage), 9 (bin storage) and 12 (surface water highways) of 24/00382/FUL
Location: Land At 63 Lucks Lane Buckden

Following a review of the documents provided to the Highway Authority as part of the discharge of condition 12 surface water highways I have noted that the applicant states that 'the blockwork for the driveway will be water-permeable but will have run-off interceptors installed to the sides and junction with highway'.

I reiterate that the drainage system should be sufficient to ensure that no surface water runs off on to the highway at the highway boundary.

On this basis the Local Highway Authority offers no objection to the discharge of condition 12.

Sonia Hansen
Assistant Engineer
Highways Development Management