PLANNING CONSULTATION RESPONSE


To Kevin Simpson Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	Place & Economy Highway Development Management Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 24/80363/COND Date In: 25/10/24 Date Out:19/11/24	Contact: Robin Hobbs

RE: *Application description*

Proposal: Discharge of conditions 12 (Metalled Surface) and 13 (TPP) of 21/02062/FUL
Location: 1 Tinkers Lane Sawtry Huntingdon PE28 5TF

In relation to the discharge of the following condition I would have the following comments.

12 (Metalled Surface) Drawing number 013 indicates a 5m sealed surface from the road edge but not the highway, details need to be provided of the material to be used for the driveway to ensure its non-granular for the first 5m from the highway boundary. This will ensure no granular material is deposited on the footway.



13 (TPP) of Not a highway condition, no comments to make