Conservation Officer Comments on sample panel 19.09.25

I have had a look at the photographs which the applicant has now sent in, of the sample panel of brickwork with the paint removed. It shows that the bricks below the paint are undamaged after the use of the paint remover, so the proposed paint remover is acceptable. The slight remains of paint on the brickwork are not important as the proposal was for the use of limewash once the paint had been removed.

Recommendation is to approve the sample panel.

Georgina

Georgina MacHugh MA, MSc

Conservation Officer

Huntingdonshire District Council

Development Services,

Pathfinder House, St. Mary's Street,

Huntingdon, PE29 3TN