PLANNING CONSULTATION RESPONSE

To Robyn Kerrigan Huntingdonshire District Council Pathfinder House St Marys Street Huntingdon PE29 3TN	**Place & Sustainability** **Highway Development Management** Cambridgeshire County Council West Highways Division Huntingdon Highways Depot Stanton Way Huntingdon Cambs PE29 6PY
App Reference: 25/00503/HHFUL Date In: 21/03/25 Date Out: 10/04/25	**Contact**: Sonia Hansen

RE: ***Application description***

Proposal: Extension of driveway to meet existing dropped kerb
Location: 7 Longstaff Way Hartford Huntingdon

Defer for revised drawings.

Following a review of the documents, the Local Highway Authority has no objections in principle, however, the following points require attention to make the development acceptable in highway terms:

The details shown for the access in Drawing (2) 3001 are not in accordance with our Highways Development Management General Principles for Development document Highways development - Cambridgeshire County Council:
Highways Development Management General Principles for Development- January 2023 - Amended

We do not permit permeable asphalt and require intercepting drainage (concrete channel/Aco drain) on the highway boundary unless this is the highest point

If the applicant is unwilling or unable to amend the application or provide additional information as outlined above, please advise me so I may consider making further recommendations.

Sonia Hansen
Assistant Engineer
Highways Development Management