[redacted]

From: [redacted]
Sent: 01 May 2025 14:36
To: DevelopmentControl
Subject: Discharge of Condition



Dear Lucy Pateman

Car Park Latham Road Huntingdon, 25/80061/COND, PLN-0226519

Thank you for your enquiry to discharge condition relating to the above development site. Please find our comments below.

Foul Water Comments: We have not been asked to comment on foul proposals

Surface Water Comments: The surface water strategy (drawing 22178-001 C3) connecting via a private pipe to AW manhole 5151 at a maximum discharge of 1.2l/s is acceptable to Anglian Water

Should you have any queries or comments regarding this please contact us at planningliaison@anglianwater.co.uk or 07929 786 955 quoting reference PLN-0226519.

Kind Regards

Development Services Pre-Development Team

Not you or need help?

Call us on [redacted]



This is an automatically generated email, please do not reply to this message.

Anglian Water Services Limited. Registered Office: Henderson House, Lancaster Way, Ermine Business Park, Huntingdon, Cambridgeshire PE29 6XU. Registered in England: No. 2366656. An AWG Company.